

eco-INSTITUT, Schanzenstr. 6-20, Carlswerk 1.19, D-51063 Köln

Hilti Entwicklungsgesellschaft mbH
 Mrs. Sarah Kretschmer
 Hiltistrasse 6
 86916 Kaufering

Dear Mrs. Kretschmer,

based on the evaluation of Test report **59367-A001-CS-L** dated **09/09/2024**, for the products **CP 681 Tub Box** and **CP 681 SD-FD**, commissioned by **Hilti Entwicklungsgesellschaft mbH**, we confirm compliance with the requirements of:

- VOC product emissions acc. to California Department of Public Health (CDPH) Standard Method v1.2-2017 (California Specification 01350 (01/2017))


These criteria meet the requirements for low-emitting **Insulation** in credit EQc2 of the LEEDv4 Rating System and the LEEDv4.1 Rating System.

Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario	Individual VOCs of Concern		Formaldehyde		TVOC
	Requirement	Requirement hold	Requirement	Requirement hold	Range
School Classroom	½ CREL	yes	≤ 9 µg/m³	yes	≤ 0.5 mg/m³
Private Office	½ CREL	yes	≤ 9 µg/m³	yes	≤ 0.5 mg/m³

Mass per surface area: not applicable

Köln, 09/09/2024



Marc-Anton Dobaj, M.Sc. Crystalline Materials
 (Project management)